

**ADDENDUM# 1  
FIRE ALARM CONTROL PANEL WITH VOICE ANNUNCIATION  
AT CORNERSTONE AQUATIC CENTER**

**Bid # 6192F**

**April 27, 2011**

**Dear Vendors:**

**The Contract Bidding Documents pursuant to Bid # 6192F are hereby revised as follows:**

**The following are in response to questions raised at the pre-bid meeting:**

- 1. Recreation Pool Area**
  - a. Install all 5 remote test key switches to the same location, 5 feet above ground.**
- 2. Meeting Room**
  - a. Add horn/strobe/speaker**
- 3. Women's Locker Room**
  - a. Install remote key test switch to guard's room electrical room**
- 4. Men's Locker Room**
  - a. Install remote key test switch to 5 feet above ground**
- 5. Sprinkler System**
  - a. Install monitoring relay to existing PSI switch**
- 6. Attached are blueprints of the facility.**

Thank you for your patience, time and consideration.

Sincerely,



Tammy Bradley, CPM, C.P.P.B.  
Sr. Buyer

Attachments

C: Mike Longo, Facility Services Manager



TOWN OF WEST HARTFORD 50 SOUTH MAIN STREET  
TOWN OF WEST HARTFORD, CT 06107-2431  
(860) 561-7470 FAX: 561-7492



Printed on Recycled Paper